



PUNJAB MASSTRANSIT AUTHORITY

Minutes of Meeting Regarding Pre – Bid Meeting for Tender Supply / Supply / Installation / Replacement Of 132kv Outdoor Cable Termination (Oil Type) and Underground XLPE Power Cable Testing at Switch Yard Area of Lahore Orange Line Metro Train Shahnour High Voltage Grid

Date 27th September 2023

Venue E&M Room, PMA Office, 5th Floor, Arfa Software Technology Park (ASTP), 346-B, Ferozpur Road, Lahore

Chair

DECISIONS / DISCUSSIONS

The meeting started at 1400 hours. Assistant Manager Electrical (Power), PMA formally welcomed the participants and started the meeting. Question and Answer session was conducted afterwards. Detailed Minutes of Meeting is mentioned below. The list of participants is attached as Annex A. The meeting ended at 1600 Hours with a note of “Thanks”

S. No	QUERIES / COMMENTS	PMA'S RESPONSE
1	Is it Factory Acceptance Test (FAT) report included with the quoted offer? (M/s Transmark International)	FAT report is not the PMA requirement.
2	Role of LESCO in this Tender. (M/s Transmark International)	The data sheet for the 132KV Cable Termination Kit will undergo a professional review by the LESCO TS Department.
3	Required Power XLPE Cable and 132KV cable Termination Data Sheet. (M/s Barqtron Engineering Solutions)	Already shared.

PRE BID MEETING

Annex - A


PROJECT TITLE: SUPPLY / INSTALLATION / REPLACEMENT OF 132KV OUTDOOR CABLE TERMINATION (OIL TYPE) AND UNDERGROUND XLPE POWER CABLE TESTING AT SWITCH YARD AREA OF LAHORE ORANGE LINE METRO TRAIN SHAHNOOR HIGH VOLTAGE GRID

ATTENDANCE SHEET

Place: Committee Room, PMA Office 5th floor, Arfa Software Technology Park, Lhr

Date: Wednesday, September 27, 2023

Start Time: 2:00 PM
End Time:

Sr. No.	Bidder (Company/ Firm)	Representative's Name	Signature	Email Address	Contact No.
1	TRANSWARK INTERNATIONAL	Engr. Khalid Javed		info@transwark.com.pk	03218891906
2	9	Engr. Muhammad Azeem		"	0321-8468352
3	Baqatron Pvt. Ltd.	Engr. Mohsin Muhsin		RAZI. Khan@baqatron.com	0321-4675945
4					
5					
6					
7					
8					
9					
10					